



Jim Doyle, Governor Mary P. Burke, Secretary

P.O. Box 2658

April 24, 2007

SHUMANN & ASSOCIATES EUGENE SHUMANN 4433 MORMON COULEE RD LACROSSE WI 54603

TERRACE HOMES GALEN T. MANTERNACH 1553 11TH DR FRIENDSHIP WI 53934-9774

Re: Description: PREFABRICATED PLUMBING SYSTEM

Manufacturer: TERRACE HOMES

Product Name: PREFABRICATED PLUMBING SYSTEM

Model Number(s): THGS16A, THGS16A.1, THGS16B, THGS16C, THGS16D, THGS16E AND THGS16F

Product File No: 20070102

The specifications and/or plans for this plumbing product have been reviewed and determined to be in compliance with chapters Comm 82 through 84. Wisconsin Administrative Code, and Chapters 145 and 160. Wisconsin Statutes.

The Department hereby issues an approval based on the Wisconsin Statutes and the Wisconsin Administrative Code. This approval is valid until the end of April 2012.

This approval is contingent upon compliance with the following stipulation(s):

- The flowing water supply pressure at the point(s) of connection must be at least 25 psig.
- The manufacturer must keep at the manufacturing plant a set of plans and specifications bearing the department's stamp of approval. The plans and specifications must be open to inspection by an authorized representative of the department.
- The maximum water supply fixture units (wsfu) on PEX tubing must not exceed 20.5 wsfu for 1-inch tubing, 11 wsfu for 3/4-inch tubing, 8 wsfu for 5/8-inch tubing, and 4 wsfu for 1/2-inch tubing.
- The maximum water supply fixture units (wsfu) on Type M copper tubing must not exceed 112.0 wsfu for 1-1/2inch tubing, 62.0 wsfu for 1-1/2-inch tubing, 34.0 wsfu for 1-inch tubing, 18.0 wsfu for 3/4-inch tubing and 7.5 wsfu for 1/2-inch tubing.

This approval supersedes the approval issued on March 21, 2002, under product file number 20020044.

This approval letter shall be incorporated with your previously approved plans and/or specifications approved under product file number 20020044.

The department is in no way endorsing this product or any advertising, and is not responsible for any situation which may result from its use.

Sincerely,

Michael J. Beckwith, CIPE Plumbing Product Reviewer phone: 608-266-6742

fax: 608-267-9566

e-mail: mike.beckwith@wisconsin.gov

SBD-10564-E (N.10/97) File Ref: 07010202.DOC